Distance requirements for distribution boxes in power distribution rooms



Overview

Minimum clearances are established for work spaces in front of high voltage - electrical equipment such as switchboards, control panels, switches, circuit breakers, switchgear and motor controllers.

Key Takeaways

Minimum clearances for electrical equipment require at least 3 feet in front, 30 inches on the sides, and 6. 5 feet in height, with dedicated space extending from the floor to 6 feet above the equipment.

Working Space Requirements

Electrical equipment such as panelboards, switchboards, and distribution boxes must have adequate working space to allow safe operation, maintenance, and emergency access.

According to NE

C 110. 26 and OSHA 1910. 303, the minimum clearances are: Front clearance: At least 3 feet (36 inches) in front of the equipment to allow doors to open fully and provide safe access for personnel.

Side clearance: Minimum 30 inches from the sides of the equipment, or at least the width of the equipment itself, to ensure safe side access. Height clearance: Minimum 6. 5 feet (≈2 meters) or the height of the equipment, whichever is greater, to allow safe headroom.

© 2026 CJC FIBRE CONSULTANTS - All rights reserved

These clearances are essential to prevent personnel from being trapped or exposed to live parts during maintenance or emergencies.

Dedicated Space

A dedicated space must be maintained around electrical equipment to protect it from physical damage and to ensure accessibility: The dedicated space should match the width and depth of the equipment. It must extend from the floor to 6 feet above the equipment or to the structural ceiling, whichever is lower. No other equipment, piping, or storage should occupy this space unless it is physically separated or protected from accidental contact.

High-

Voltage and Special ConditionsFor equipment rated over 1,000 volts, the required front clearance may increase depending on the voltage and the presence of live parts on opposing sides: Condition 1: Exposed live parts on one side, grounded parts on the other – clearance ranges from 3 to 8 feet depending on voltage. Condition 2: Exposed live parts on one side, grounded wall on the other – clearance ranges from 4 to 10 feet. Condition 3: Exposed live parts on both sides – additional clearance is required to ensure safety.

Protection from Physical DamageIn areas with forklifts, stacked materials, or pedestrian traffic, distribution boxes and disconnects must be protected by barriers or enclosures if the distance alone does not prevent accidental contact.

OSH

A requires that live parts operating at 50 volts or more be guarded against accidental contact using approved cabinets or enclosures.

Practical Recommendations

Maintain a clear path of travel in electrical rooms; do not use the space for storage. Ensure panel doors can open 90° without obstruction. For large switchboards or equipment over 1,200 amps, consider additional exits or doubling front clearance to prevent personnel from being trapped.

Verify that all clearances comply with NEC 110. 26 and OSHA 1910. 303 for your specific voltage and installation conditions.

By following these guidelines, power distribution rooms and distribution boxes will meet safety standards, allow proper maintenance, and reduce the risk of electrical hazards.

© 2026 CJC FIBRE CONSULTANTS - All rights reserved

Article Content

NEC Working Clearance Requirements: A Visual Guide (110.26)

This table outlines the specific distances for Condition 1, 2, and 3 scenarios. Additionally, the code specifies requirements for the Width of working space and Electrical equipment headroom, ensuring

National Electrical Code (NEC) Requirements for Panelboards

Clearance: Electrical panels must be installed in a readily accessible area with a minimum clearance of 30 inches (762 mm) wide, 3 ft (36 inches or 914 mm) deep, and 6.5 feet (≈ 2 meter) high in front of

IEC / BS 7671 Codes for Consumer Unit and Distribution Board

Residential: The recommended height for distribution board and consumer unit is between 1 metre to 1.8 metre from the floor. The suggested height is 1.3 metres for elderly and handicapped people in the

NEC Article 110.34: Electrical Room "Basics"

Minimum clearances are established for work spaces in front of high voltage - electrical equipment such as switchboards, control panels, switches, circuit breakers, switchgear and motor controllers. These

Electrical Panel Clearance Code: NEC 110.26 For Homes And Garages

Keep the working space clear from the floor or grade up to 6 ft 6 in. (2.0 m) or the height of the panel—whichever is greater. Minor elements like conduit or raceways can project up to 6

Know how to size an electrical room properly

In this electrical room sizing example, learn how to size the room and position the equipment to meet NEC requirements.

The installation requirements for the distribution box

In this guide, we''ll break down everything you need to know to install a distribution box correctly and confidently. Choose the right box based on environment (indoor/outdoor), load

Installation Requirements for Power Distribution Boxes in Equipment

In this guide, we''ll break down everything you need to know to install a distribution box correctly and confidently. 1 Pre-installation Requirements for Transformers and Substations: - The indoor ceiling

© 2026 CJC FIBRE CONSULTANTS - All rights reserved

Essential Guide: Electrical Panel Access Clearance Requirements

Access clearance requirements refer to the space that must be maintained around electrical panels to ensure safe Operation and Maintenance. This clearance is essential for emergency access, routine

Communication Facilities Construction Design Standards

The team will work with the occupants, contractors, and project managers during the planning stages, and provide them with the space requirements for communications room(s), distribution design

Full text of "NEW"

Full text of "NEW" See other formats Word . the, > < br to of and a : " in you that i it he is was for - with) on (? his as this ; be at but not have had from will are they -- ! all by if him one your or up her there

Installation requirements for distribution boxes

Distribution boxes shall be made of non-combustible materials; open distribution boards may be installed in production places and offices with low electric shock risk; enclosed cabinets shall

Electrical Room – Power Distribution, Safety, And Equipment

Electrical room design ensures safe power distribution with circuit breakers, switchgear, and code compliance. Learn key requirements for safety and functionality.

Politics News | Breaking Political News, Video & Analysis-ABC News

ABC News is your trusted source on political news stories and videos. Get the latest coverage and analysis on everything from the Trump presidency, Senate, House and Supreme Court.

1910.303

Switchboards, panelboards, and distribution boards installed for the control of light and power circuits, and motor control centers shall be located in dedicated spaces and protected from damage.

Key Points Of Installation And Collocation Of Distribution Box In ...

The power distribution system at the construction site shall be distributed in different levels. The main distribution box (or distribution room) shall be set up.

Regulations / guidance regarding siting of distribution

© 2026 CJC FIBRE CONSULTANTS - All rights reserved

Hello All Is there any regulations regarding the siting of distribution boards like level area in front of board and dimensions of area in front of board etc?

The Complete Guide to NEC Essentials for Architects

Basic Nomenclatures and Characteristics Because the code requirements vary depending on the type of electrical distribution equipment in question, it is important to be familiar with the different types of

Contact Us

Continue your research online:

Website: https://cjcconsultants.co.za
Technical inquiry: https://cjcconsultants.co.za/contact.html

This document is for preliminary research. Verify specifications against current standards, product documentation and project requirements.

© 2026 CJC FIBRE CONSULTANTS - All rights reserved